

ਦਫਤਰ ਉਪ ਮੰਡਲ ਇੰਜਨੀਅਰ ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਨੰਬਰ 2 ਭ. ਮ. ਸਾਖਾ ਮੋਗਾ

To,

The Principal,

Royal Convent School,

Dhurokot, Nihal Singh Wala, Distt Moga (Punjab) ।

ਨੰਬਰ 320

ਮਿਤੀ 27/04/2026


ਵਿਸ਼ਾ:

ਇਮਾਰਤ ਸੁਰੱਖਿਅਤ ਹੋਣ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਬਾਬਤ 2026-27 ।

ਉਪਰੋਕਤ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਨਿਰੀਖਣ ਸਬੰਧਤ ਜੂਨੀਅਰ ਇੰਜਨੀਅਰ ਵਲੋਂ ਕੀਤਾ ਗਿਆ । ਬਿਲਡਿੰਗ 2026-27 ਲਈ ਸੁਰੱਖਿਅਤ ਪਾਈ ਗਈ ਹੈ । ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਸੁਰੱਖਿਅਤ ਹੋਣ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਆਪ ਨੂੰ ਮਿਤੀ 31-03-2027 ਤੱਕ ਜਾਰੀ ਕੀਤਾ ਗਿਆ ਹੈ । ਅੱਗੇ ਤੋਂ ਹੇਠ ਲਿਖੀਆਂ ਹਦਾਇਤਾਂ ਵਲੋਂ ਵਿਸ਼ੇਸ਼ ਧਿਆਨ ਦਿੱਤਾ ਜਾਵੇ ।

- 1) ਬਿਲਡਿੰਗ ਦੇ ਆਲੇ-ਦੁਆਲੇ ਅਤੇ ਛੱਤਾ ਉਪਰ ਪਾਣੀ ਨਾ ਖੜਾ ਹੋਣ ਦਿੱਤਾ ਜਾਵੇ।
- 2) ਜੇਕਰ ਬਿਲਡਿੰਗ ਵਿਚ ਕਿਸੇ ਕਿਸਮ ਦੀ ਤਰੇੜ ਆ ਜਾਂਦੀ ਹੈ ਤਾਂ ਉਸ ਜਗ੍ਹਾ ਨੂੰ ਤੁਰੰਤ ਖਾਲੀ ਕੀਤਾ ਜਾਵੇ ਤੇ ਉਸ ਦੀ ਤੁਰੰਤ ਰਿਪੇਅਰ ਕਰਵਾਈ ਜਾਵੇ ।
- 3) ਕਿਸੇ ਕਿਸਮ ਦੀ ਉਸਾਰੀ ਵਿਚ ਵਰਤੇ ਗਏ ਮਟੀਰੀਅਲ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਸਬੰਧਤ ਸਕੂਲ ਦੀ ਹੋਵੇਗੀ । ਆਪ ਵਲੋਂ ਨੱਥੀ ਨਕਸ਼ੇ ਤੋਂ ਇਲਾਵਾ ਜੇਕਰ ਆਪ ਵਲੋਂ ਵਾਧੂ ਉਸਾਰੀ ਕਰਨੀ ਹੋਵੇ ਤਾਂ ਉਸ ਦੀ ਮੰਨਜ਼ੂਰੀ ਮਹਿਕਮੇ ਵਲੋਂ ਲਈ ਜਾਵੇਗੀ ।
- 4) ਡਾਇਰੈਕਟਰ ਜਨਰਲ ਸਕੂਲ ਸਿੱਖਿਆ ਵਿਭਾਗ ਪੰਜਾਬ ਅਤੇ ਸਟੇਟ ਪ੍ਰੋਜੈਕਟ ਸਰਵ ਸਿੱਖਿਆ ਅਭਿਆਨ ਦੇ ਪੱਤਰ ਨੰਬਰ 75444 ਮਿਤੀ 06-11-2009 ਮੁਤਾਬਿਕ ਸਕੂਲ ਵਿੱਚ ਅੱਗ ਬੁਝਾਓ ਯੰਤਰ ਠੀਕ ਹਾਲਤ ਵਿਚ ਰੱਖੇ ਜਾਣ । ਕਿਸੇ ਵੀ ਅਣਸੁਖਾਵੀ ਘਟਨਾ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਸਬੰਧਤ ਸਕੂਲ ਦੀ ਹੋਵੇਗੀ ।
- 5) ਅਗਲੇ ਸਾਲ 2027-28 ਦੀ ਇੰਨਸਪੈਕਸ਼ਨ ਕਰਾਉਣੀ ਯਕੀਨੀ ਬਣਾਈ ਜਾਵੇ ।

ਨੱਥੀ ਸਰਟੀਫਿਕੇਟ,


ਉਪ ਮੰਡਲ ਇੰਜਨੀਅਰ,
ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਨੰ. ਭ.ਮ. ਸਾਖਾ,
ਮੋਗਾ ।

PROFORMA FOR SAFETY OF SCHOOL BUILDING

PART-I

(To be filled by the Head of School / Institute)

- 1) Name of the School **ROYAL CONVENT SCHOOL**
- 2) Location. **DHURKOT NIHAL SINGH WALA**
- 3) Plot Area. **15418 Sq. Yard**
- 4) Plinth Area. **4777 Sq. Yard**
- 5) Number of storey's **Four (4)**
- 6) Year of construction of Building **2006**
- 7) If the building has been constructed under the Supervision of the qualified Engineer, the following details may be given:- **Yes**
 - a) Name of the Engineer with Qualification. **Daljeet Singh B.Tech**
 - b) Address of Engineer. **magastic Road moga**
 - c) Set of structural drawing used in the construction .. Available.
 - d) Name & address of Architect with qualification :
- 8) Whether the building has been constructed for the Purpose school. **Yes / No**
Residential purpose and converted for use as a school **Yes / No**
- 9) Material used for Roof. **Yes / No**
 - a) R.C.C slab/ R.B.C Slabs **Yes / No**
 - b) R.S. Joist & Battens. **Yes / No**
 - c) Wooden Joist & Battens **Yes / No**
- 10) Material used for walls. **Yes / No**
 - a) Mud Mortar. **Yes / No**
 - b) Cement Mortar. **Yes / No**
 - c) Lime Mortar. **Yes / No**
- 11) Flooring. **Yes / No**
 - a) Conglomerate **Yes / No**
 - b) Terrazzo. **Yes / No**
 - c) Brick Paving **Yes / No**
- 12) A detailed drawing indicating dimension of Room Alongwith size and location of doors and windows (attached).
- 13) For Fire Safety.
 - a) Weather the width of the staircase is 1.5 Mtr. **Yes / No**
 - b) Weather portable fire exiting. **Yes / No**
 - c) Weather School building is free from inflammable & toxic material **Yes / No**
 - d) Weather Cooking of food is done at a safe place **Yes / No**
 - e) Weather any thatch of combustible material as been Used. **Yes / No**

14) Requirement for fire Protection Arrangements under NBC

Part -IV

(For Building height Less than 15metre)

- | | | |
|--|---|----------|
| a) Weather house Real provided. | : | Yes / No |
| b) Weather down corner provided. | : | Yes / No |
| c) Weather automatic sprinkler provided. | : | Yes / No |
| d) Weather underground static water storage tank of Capacity 50,000Ltr.(It converted are excess 1600sqm) | : | Yes / No |
| e) Weather over head tank of capacity 10,000 Ltr. | : | Yes / No |

Exists.(in case of house real) 20,000 Ltr.

- | | | |
|---|---|---------|
| f) Weather one electric and one diesel pump of 3 kg/ cum Pressure of capacity 1620 LPM.One electric pump of Capacity 180LPM exist near underground static tank. | : | Yes/No |
| g) Weather a pump 3 Kg /cum pressure 450/500 LPM Exist near over head tank. | : | Yes/ No |

Bharat Kalita

Principal

Royal Convent School

Vill. Dhurkot,

Teh.Nihal Singh Wala (Moga)

School stamp

PART -II

(To be filled by the S.D.E for PWD (B&R) Department)

- a) I have visited the above mentioned school on date 27/04/26 a have visually inspected it from all angles of safety and found it fit for normal use as school building.
- b) In case any addition / alteration or expansion and modifications to this building is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be re-obtained after the completion from the undersigned.
- c) In case the building is affected by flood , or if there is settlement of walls/ foundation and sagging of roofs etc., immediate inspection of the undersigned be arranged to check the stability and safety of the building.
- d) This building can be safely occupied for normal use upto (indicate upto which it can be used) one year only (31/03) 2027

[Signature]
Sub Divisional Engineer
Construction Sub Division No
B & R Mega

Bharat Kalita

Principal

Royal Convent School

Vill. Dhurkot,

Teh.Nihal Singh Wala (Moga)